



**NAGADI CONSULTANTS PRIVATE LIMITED**  
Delhi - Bangalore - Chennai - Secunderabad

Doc. No. : FD/G/09/01

Job No. : G(D)MS32

**RECORD OF BORING IN SOIL STRATA**

Date :

Project Proposed Project at Kanin India Ltd B.H. No. 01

Place Sector 25, Faridabad, Haryana Location .....

B.H. Co-ordinates ..... Termination depth 20.0m

Equipment Big Set Started on 20-2-2023 Completed on 22-2-2023 Water table NE

Soil Description	Time	Depth	SPT/UDS	N-Value	Remarks
0.0m Y/B sandy silt with gr.		0.9m	SPT	04	1-1-1-1-1
		1.5m	UDS		
		2.4m	SPT	11	1-2-2-3-3-3
3.0m Y/B sandy clayey silt with gravels.		3.0m	UDS		
3.3m Y/B sandy silt with gr.		3.9m	SPT	13	2-2-3-3-3-4
3.9m Y/B sandy clayey silt with gravels.		4.5m	UDS		
5.2m Y/B sandy silt with gr.		5.4m	SPT	18	2-3-4-4-5-5
5.4m Y/G silty sand 50:50 with gravels.		6.0m	UDS		
		6.9m	SPT	22	3-4-5-5-6-6
		7.5m	UDS		
		8.4m	SPT	28	3-4-5-6-8-9
9.7m Grey sand with gravels		9.0m	UDS		
		9.9m	SPT	32	4-4-5-7-9-11
		10.5m	UDS		
		11.4m	SPT	35	4-6-7-8-9-11
		12.0m	UDS		
		12.9m	SPT	40	4-6-8-9-11-12
14.0m Y/B sandy silt with gr.		13.5m	UDS		
14.3m Y/G sand with gravels with trace of silt.		14.4m	SPT	27	3-4-6-6-7-8
		15.0m	UDS		
		15.9m	SPT	69	4-7-14-17-18-20
		16.5m	UDS		

Client

Executive / Engineer

M.S.  
Site Charge





**NAGADI CONSULTANTS PRIVATE LIMITED**  
Delhi - Bangalore - Chennai - Secunderabad

Doc. No. : FD/G/09/01

Job No. G (D) 4532

**RECORD OF BORING IN SOIL STRATA**

Date :

Project Proposed Project at Kavim India Ltd B.H. No. 02

Place Sector 29 Faridabad Haryana Location

B.H. Co-ordinates Termination depth 20.0m

Equipment Big Set Started on 22-2-2023 Completed on 24-2-2023 Water table N-E

Soil Description	Time	Depth	SPT/ UDS	N-Value	Remarks
0.0m Y/B sandy silt filled up		0.9m	UDS		
0.3m Y/B sandy silt with gss.		1.5m	SPT	07	1-1-2-2-2
		2.4m	UDS		
		3.0m	SPT	07	1-1-2-2-2
		3.9m	UDS		
		4.5m	SPT	13	1-1-2-4-6
		5.4m	UDS		
6.8m Y/G silty sand (50-50) with gravel.		6.0m	SPT	20	2-3-4-5-5-6
		6.9m	UDS		
		7.5m	SPT	22	2-4-4-6-6-6
8.2m Gray sand with gravel.		8.4m	UDS		
		9.0m	SPT	21	3-3-3-6-6-6
		9.9m	UDS		
		10.5m	SPT	25	3-3-5-6-7-7
		11.4m	UDS		
		12.0m	SPT	26	3-4-5-6-7-8
Y/B sandy clayey silt with gss		12.9m	UDS		
Gray sand with gravel with traces of silt.		13.5m	SPT	29	4-4-6-6-8-9
		14.4m	UDS		
		15.0m	SPT	24	3-4-5-6-6-7
		15.9m	UDS		
		16.5m	SPT	43	3-5-8-11-12-12

Job - 4532 BH-02

Soil Description	Time	Depth	SPT/ UDS	N-Value	Remarks
Gray sand with grains of trace of silt. /		17.4m	UDS	39	4-8-8-9-10-12
		18.0m	SPT		
		20.0m	UDS		